

CITY OF AUSTELL, GEORGIA

Addendum 1

For

Milling and Paving Spring Street, Rolly Street, and Filter Plant Rd

ITB# 23-00004-PW

SUBJECT: Questions and Answers

Date: September 8, 2023

Q: Are we to mill up to brick pavers or remove the brick pavers?

A: Mill up to the markers/strips next to the brick pavers.

Q: Are we paving up to the storm inlets?

A: Yes

End of Addendum